



NOTES:

- 1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL CODES.
- 2. SEE PRODUCT DOCUMENTATION FOR FURTHER INFORMATION
- 3. THIS DRAWING DEPICTS THE POWER SYSTEM CONNECTIONS AND IS NOT REPRESENTATIVE OF THE PHYSICAL LAYOUT. PLEASE REFER TO MECHANICAL DRAWINGS FOR PHYSICAL LAYOUT.
- △4. EACH BLOCK CONSISTS OF (6) C13 RECEPTACLES CONNECTED IN PARALLEL.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.



TITLE: RACK PDU 2G, METERED ZERO U, 32A, 230V INPUT: IEC 309 32A 2P+E OUTPUT: (36)IEC 320 C13, (6)IEC 320 C19 ELECTRICAL SCHEMATIC		DWG NO: AP8853			REV.
		N BY:	V BUSH	28-0CT-10	PROJ
		NEER: Y JIANG/T H	HORSTMANN	28-0CT-10	ANGLE
PROJECT: SUBMITTAL DRAWINGS SHEET 2 OF	2 APPR	ROVED BY: B SHERIC	OAN/M LEPARD	28-0CT-10	N.A.